

Camerano, March 2014

Certificate of Conformity

ALARM CABLES NOT SHIELDED

We, **ELAN s.r.l.**, **CERTIFY** that the cables marked with:

ELAN A.F. CEI 20-22 III CEI 36762 C-4 (U₀=400V)

are manufactured in accordance with the following Standards:

CEI 20-11; CEI 20-29; CEI 20-20; CEI 20-22III (IEC 60332; BSEN 50265); CEI 36762



MANUFACTURING TECHNICAL FEATURES

1. UNIPOLAR WIRES:

- a. The unipolar wires (0,50 – 0,75 – 1,00 – 1,50 - Ø 8/10) which are the feeding conductors are insulated in PVC type R2. They pass the test of voltage according to CEI 20-20 standard: 5 minutes with 2000 V. in dry current without any crack of insulation covering.
- b. The unipolar wires (0.22) which are the signal conductors are insulated in PVC type R2. They pass the test of voltage according to CEI 20-20 standard: 5 minutes with 1000 V. in dry current without any crack of insulation covering.

2. JACKET:

The jacket in various colours white, blue, red and grey is made of flexible PVC type RZ and flame retardant according to CEI 20/22-III (IEC 60332; BSEN 50265) Standard.

Alarm cables marked as C-4 (U₀=400V) owing to their technical characteristics and the positive results obtained by passing the tests and can be installed with electrical power cables marked both 450/750V, and 0,6/1 Kv according to CEI UNEL 36762.

Elan Srl

